

Report sponsor	Certificate issue date	Product/system
Elton Group Pty Ltd	02 August 2019	Eveneer™ reconstituted veneers

Introduction

The elements of construction described below was assessed by this laboratory on behalf of the test sponsor in accordance with the requirements of AS 5637.1:2015. Refer to the referenced assessment report(s) or regulatory information report(s) for the complete description of the assessment construction.

Referenced assessment report	Test methods	Report issue date	Report validity date
FAS190173 R1.0	AS ISO 9705:2003 (R2016)	22 July 2019	31 July 2024

Formal assessment summary

The referenced report presents an assessment on the likely fire hazard properties of Eveneer™ branded reconstituted veneers bonded to a Flameblock™ FRMDF, in accordance with AS 5637.1:2015. Multiple reaction to fire tests were conducted on these materials, the results of which were applied to predict the likely performance of a range of veneers, as summarized in Table 1.

Table 1 Assessed fire hazard properties of timber veneers bonded to a 12-25 mm thick Flameblock™ FRMDF substrate

Veneer Type	Density Range (kg/m ³)	Maximum Thickness (mm)	Group Number	SMOGR _{ARC} (m ² /s ²)
Eveneer™ reconstituted dyed	380 - 415	0.6	2	< 100

Refer to the referenced report for a complete description of the assessed construction.

Conditions/ Validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia Pty Ltd ACN 050 241 524 are subject to, and conducted in accordance with, the standard terms and conditions of Warringtonfire Australia Pty Ltd, which are available at <https://www.element.com/terms/terms-and-conditions> or upon request.
- Exova Warringtonfire rebranded to Warringtonfire on 1 December 2018. Apart from the change to our brand name, no other changes have occurred. The introduction of our new brand name does not affect the validity of existing documents previously issued by us.

Prepared by	Reviewed by	Authorized by
Tanmay Bhat	Omar Saad	Omar Saad
		